
PLAN REVIEW CHECKLIST

PROJECT ID # _____

JOB NAME _____

DESIGNER _____

- Are all dimensions legible?
- Are all ceiling elevations labeled?
- Are ceiling construction types labeled?
- Are the rooms labeled?
- Is the street address correct?
- Is the Pueblo plan review number included?
- Is the 10% reduction curve penciled in?
- Are pipe elevation views included?
- Are all the pipes dimensioned off of walls and columns?
- Are the types of pipe noted?
- Do sprinkler head symbols on the title block match symbols on the drawing?
- Are the sprinkler head symbols easy to identify?
- Is the point of compass correct?
- Are occupancies noted?
- Are the sprinkler counts correct?
- Are capacities of dry systems included?
- Are the hangers located and detailed?
- Are control valves, check valves, drains, gauges and test connections located and labeled?
- Are the BFP, DPV, and air compressor identified on the riser detail?
- Is the horn and light located and identified?
- Is the site plan complete with main sizes and dimensions?
- Is the scale included and correct?
- Is the type of antifreeze and solution noted?
- Is the FDC located per the AHJ?
- Do node points on the plans match the node points in the calcs?
- Are node points included on the riser detail?
- Do notes on the plans adequately reference the method of locating the remote area and show any calculations for reductions in area or density?
- Is the check point gauge for residual pressure at the base of the riser included?
- Are star dimensions included?